Tecnica Pro

Design Bruno Gecchelin | **iGuzzini**

Last information update: May 2024

Product configuration: P680
P680: spotlight - neutral white - flood optic

Product code
P680: spotlight - neutral white - flood optic **Attention! Code no longer in production**

Technical description
Adjustable spotlight with adapter for installation on mains voltage track for LED source with CoB technology, Neutral White (4000K) emission. Electronic control gear housed inside the track-mounted power supply box. The luminaire is made of die-cast aluminium and thermoplastic. OPTI BEAM superpure aluminium reflector with high luminous efficacy and uniform distribution, flood optic. Features 90° inclination on the horizontal plane and 360° rotation around the vertical axis, with mechanical locking device for aiming. Passive cooling system. Possibility of installing a refractor, to be ordered separately, for elliptical light beam distribution.

Installation
The luminaire can be installed on a standard electrified track or on an appropriate channel incorporating an electrified track.

Colour
White (01) | Black (04)

Weight (Kg)
1.82



Mounting
three circuit track|ceiling surface

Wiring
product inclusive of electronic components incorporated into the track-mounted box.

Complies with EN60598-1 and pertinent regulations

IP20 IP40 for optical assembly

Technical data

lm system:	3945	CRI:	80
W system:	35.6	Colour temperature [K]:	4000
lm source:	5000	MacAdam Step:	2
W source:	32	Life Time LED 1:	> 50,000h - L80 - B10 (Ta 25°C)
Luminous efficiency (lm/W, real value):	110.8	Lamp code:	LED
lm in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	79	Number of optical assemblies:	1
Beam angle [°]:	38°		

Polar



Lux

h	d	Em	Emax
2	1.4	1751	2132
4	2.8	438	533
6	4.1	195	237
8	5.5	109	133

Isolux



UGR diagram

Corrected UGR values (at 5000 lm bare lamp luminous flux)

Riflect.: ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim				viewed crosswise					viewed endwise		
x	y										
2H	2H	16.5	17.1	16.7	17.3	17.5	16.5	17.1	16.7	17.3	17.5
	3H	16.3	16.9	16.6	17.1	17.4	16.3	16.9	16.6	17.1	17.4
	4H	16.3	16.8	16.6	17.0	17.3	16.3	16.8	16.6	17.1	17.4
	6H	16.2	16.6	16.5	17.0	17.3	16.2	16.6	16.5	17.0	17.3
	8H	16.1	16.6	16.5	16.9	17.3	16.2	16.6	16.5	16.9	17.3
	12H	16.1	16.5	16.5	16.9	17.2	16.1	16.5	16.5	16.9	17.2
4H	2H	16.3	16.8	16.6	17.1	17.4	16.3	16.8	16.6	17.0	17.3
	3H	16.1	16.5	16.5	16.9	17.2	16.1	16.5	16.5	16.9	17.2
	4H	16.0	16.4	16.4	16.8	17.1	16.0	16.4	16.4	16.8	17.1
	6H	15.9	16.3	16.4	16.7	17.1	15.9	16.3	16.4	16.7	17.1
	8H	15.9	16.2	16.3	16.6	17.0	15.9	16.2	16.3	16.6	17.0
	12H	15.8	16.1	16.3	16.5	17.0	15.8	16.1	16.3	16.5	17.0
8H	4H	15.9	16.2	16.3	16.6	17.0	15.9	16.2	16.3	16.6	17.0
	6H	15.8	16.0	16.3	16.5	17.0	15.8	16.0	16.3	16.5	17.0
	8H	15.7	16.0	16.2	16.4	16.9	15.7	16.0	16.2	16.4	16.9
	12H	15.7	15.9	16.2	16.4	16.9	15.7	15.9	16.2	16.4	16.9
12H	4H	15.8	16.1	16.3	16.5	17.0	15.8	16.1	16.3	16.5	17.0
	6H	15.7	16.0	16.2	16.4	16.9	15.7	16.0	16.2	16.4	16.9
	8H	15.7	15.9	16.2	16.4	16.9	15.7	15.9	16.2	16.4	16.9

Variations with the observer position at spacing:

S =			
	1.0H	6.5 / -12.5	6.5 / -12.5
	1.5H	9.3 / -17.3	9.3 / -17.3
	2.0H	11.3 / -19.6	11.3 / -19.6