Laser Blade XS

Design iGuzzini **iGuzzini**

Last information update: June 2025

Product configuration: Q572
Q572: Minimal 10 cells - Wideflood beam - LED

Product code
Q572: Minimal 10 cells - Wideflood beam - LED

Technical description
Linear miniaturised recessed luminaire with 10 optical elements for LED lamps - fixed optic. Despite the ultracompact size of the product, the patented technology of the optic system guarantees an efficient flow and a high level of controlled glare visual comfort. Main body with die-cast zamak radiant surface, minimal (frameless) version for mounting flush with the ceiling. Metallised, thermoplastic, high definition Opti Beam reflectors, integrated in a set-back position in the anti-glare screen. Supplied with DALI power supply unit connected to the luminaire.

Installation
Recessed with steel wire springs on the specific adapter (included) which allows flush-mounting with the ceiling. Adapter fixed to false ceiling (compatible thicknesses of 12.5 / 15 / 20 mm) with screws; subsequent filling and smoothing operations; insertion of luminaire body and aesthetic end finishing. A special protective sheath allows finishing operations on the plasterboard to be simplified and speeded up. Preparation hole 28 x 184.



Weight (Kg)
0.55

Mounting
wall recessed|ceiling recessed

Wiring
On the power supply unit with terminal board included.

Notes
The special steel wire spring provided is required to facilitate the eventual extraction of the recessed body once it has been inserted.

Complies with EN60598-1 and pertinent regulations

IP20 pending pending

Technical data

lm system:	1245	Colour temperature [K]:	3000
W system:	22.8	MacAdam Step:	3
lm source:	1500	Life Time LED 1:	> 50,000h - L80 - B10 (Ta 25°C)
W source:	19	Voltage [Vin]:	230
Luminous efficiency (lm/W, real value):	54.6	Lamp code:	LED
lm in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	83	Number of optical assemblies:	1
Beam angle [°]:	58°	Control:	DALI
CRI (minimum):	90		

Polar



CIE
nL 0.83
100-100-100-100-83
UGR 15.7-15.7
DIN
A.61
UTE
0.83A+0.00T
F"1=996
F"1+F"2=1000
F"1+F"2+F"3=1000
CIBSE
LG3 L<1500 cd/m² at 65°
UGR<16 I L<1500 cd/mq @65°

Lux

h	d	Em	Emax
1	1.1	1262	1573
2	2.2	315	393
3	3.3	140	175
4	4.4	79	98

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	75	71	68	66	70	68	68	65	78
1.0	78	75	72	70	74	72	71	69	83
1.5	82	79	77	76	78	77	76	73	89
2.0	85	83	81	80	82	80	79	77	93
2.5	86	85	84	83	84	83	82	79	96
3.0	87	86	85	85	85	84	83	81	98
4.0	88	87	87	86	86	86	84	82	99
5.0	89	88	88	88	87	86	85	83	100

Luminance curve limit



UGR diagram

Corrected UGR values (at 1500 lm bare lamp luminous flux)

Riflect.: ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim				viewed crosswise					viewed endwise		
x	y										
2H	2H	16.3	16.7	16.5	16.9	17.2	16.3	16.7	16.5	16.9	17.2
	3H	16.1	16.5	16.4	16.8	17.1	16.1	16.5	16.4	16.8	17.1
	4H	16.1	16.4	16.4	16.7	17.0	16.1	16.4	16.4	16.7	17.0
	6H	16.0	16.3	16.3	16.6	17.0	16.0	16.3	16.3	16.6	17.0
	8H	15.9	16.3	16.3	16.6	16.9	15.9	16.3	16.3	16.6	16.9
	12H	15.9	16.2	16.3	16.6	16.9	15.9	16.2	16.3	16.6	16.9
4H	2H	16.1	16.4	16.4	16.7	17.0	16.1	16.4	16.4	16.7	17.0
	3H	15.9	16.2	16.3	16.6	16.9	15.9	16.2	16.3	16.6	16.9
	4H	15.8	16.1	16.2	16.5	16.9	15.8	16.1	16.2	16.5	16.9
	6H	15.7	16.0	16.1	16.4	16.8	15.7	16.0	16.1	16.4	16.8
	8H	15.7	15.9	16.1	16.3	16.8	15.7	15.9	16.1	16.3	16.8
	12H	15.6	15.8	16.1	16.3	16.7	15.6	15.8	16.1	16.3	16.7
8H	4H	15.7	15.9	16.1	16.3	16.8	15.7	15.9	16.1	16.3	16.8
	6H	15.6	15.8	16.0	16.2	16.7	15.6	15.8	16.0	16.2	16.7
	8H	15.5	15.7	16.0	16.2	16.7	15.5	15.7	16.0	16.2	16.7
	12H	15.5	15.6	16.0	16.1	16.6	15.5	15.6	16.0	16.1	16.6
12H	4H	15.6	15.8	16.1	16.3	16.7	15.6	15.8	16.1	16.3	16.7
	6H	15.5	15.7	16.0	16.2	16.7	15.5	15.7	16.0	16.2	16.7
	8H	15.5	15.6	16.0	16.1	16.6	15.5	15.6	16.0	16.1	16.6

Variations with the observer position at spacing:

S =			
	1.0H	6.5 / -24.9	6.5 / -24.9
	1.5H	9.4 / -25.6	9.4 / -25.6
	2.0H	11.4 / -25.8	11.4 / -25.8