Laser Blade XS

Design iGuzzini **iGuzzini**

Last information update: February 2025

Product configuration: Q494
Q494: Frame 5 cells - Wideflood beam - LED



Product code
Q494: Frame 5 cells - Wideflood beam - LED

Technical description
Linear miniaturised recessed luminaire with 5 optical elements for LED lamps - fixed optics. Despite the ultracompact size of the product, the patented technology of the optic system guarantees an efficient flow and a high level of controlled glare visual comfort. Main body with die-cast aluminium radiant surface, version with perimeter surface frame. Metallised, thermoplastic, high definition Opti Beam reflectors, integrated in a set-back position in the anti-glare screen. Supplied with DALI power supply unit connected to the luminaire.

Installation
Recessed with steel wire springs for false ceilings from 1 to 25 mm thick - preparation hole 24 x 96.

Colour
White (01) | Black / Black (43) | Black / White (47) | White/Gold (41)* | Grey / Black (74)* | White / burnished chrome (E7)*

Weight (Kg)
0.35

* Colours on request



Mounting
ceiling surface

Wiring
On the power supply unit with terminal board included.

Complies with EN60598-1 and pertinent regulations

IP20 IP23

Technical data

lm system:	955	Colour temperature [K]:	4000
W system:	12.4	MacAdam Step:	2
lm source:	1150	Life Time LED 1:	> 50,000h - L80 - B10 (Ta 25°C)
W source:	9.9	Voltage [Vin]:	230
Luminous efficiency (lm/W, real value):	77	Lamp code:	LED
lm in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	83	Number of optical assemblies:	1
Beam angle [°]:	58°	Control:	DALI-2
CRI (minimum):	90		

Polar



CIE
nL 0.83
100-100-100-100-83
UGR 17.2-17.2
DIN
A.61
UTE
0.83A+0.00T
F"1=996
F"1+F"2=1000
F"1+F"2+F"3=1000
CIBSE
LG3 L<1500 cd/m² at 65°
UGR<19 | L<1500 cd/mq @65°

Lux

h	d	Em	Emax
1	1.1	967	1206
2	2.2	242	302
3	3.3	107	134
4	4.4	60	75

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	75	71	68	66	70	68	68	65	78
1.0	78	75	72	70	74	72	71	69	83
1.5	82	79	77	76	78	77	76	73	89
2.0	85	83	81	80	82	80	79	77	93
2.5	86	85	84	83	84	83	82	79	96
3.0	87	86	85	85	85	84	83	81	98
4.0	88	87	87	86	86	86	84	82	99
5.0	89	88	88	88	87	86	85	83	100

Luminance curve limit



UGR diagram

Corrected UGR values (at 1150 lm bare lamp luminous flux)

Riflect.: ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim				viewed crosswise					viewed endwise		
x	y										
2H	2H	17.8	18.3	18.1	18.5	18.7	17.8	18.3	18.1	18.5	18.7
	3H	17.7	18.1	18.0	18.4	18.6	17.7	18.1	18.0	18.4	18.6
	4H	17.6	18.0	17.9	18.3	18.6	17.6	18.0	17.9	18.3	18.6
	6H	17.5	17.9	17.9	18.2	18.5	17.5	17.9	17.9	18.2	18.5
	8H	17.5	17.9	17.9	18.2	18.5	17.5	17.9	17.9	18.2	18.5
	12H	17.5	17.8	17.8	18.1	18.5	17.5	17.8	17.8	18.1	18.5
4H	2H	17.6	18.0	17.9	18.3	18.6	17.6	18.0	17.9	18.3	18.6
	3H	17.5	17.8	17.8	18.1	18.5	17.5	17.8	17.8	18.1	18.5
	4H	17.4	17.7	17.8	18.0	18.4	17.4	17.7	17.8	18.0	18.4
	6H	17.3	17.5	17.7	17.9	18.4	17.3	17.5	17.7	17.9	18.4
	8H	17.2	17.5	17.7	17.9	18.3	17.2	17.5	17.7	17.9	18.3
	12H	17.2	17.4	17.6	17.8	18.3	17.2	17.4	17.6	17.8	18.3
8H	4H	17.2	17.5	17.7	17.9	18.3	17.2	17.5	17.7	17.9	18.3
	6H	17.1	17.3	17.6	17.8	18.3	17.1	17.3	17.6	17.8	18.3
	8H	17.1	17.3	17.6	17.7	18.2	17.1	17.3	17.6	17.7	18.2
	12H	17.0	17.2	17.5	17.7	18.2	17.0	17.2	17.5	17.7	18.2
12H	4H	17.2	17.4	17.6	17.8	18.3	17.2	17.4	17.6	17.8	18.3
	6H	17.1	17.3	17.6	17.7	18.2	17.1	17.3	17.6	17.7	18.2
	8H	17.0	17.2	17.5	17.7	18.2	17.0	17.2	17.5	17.7	18.2

Variations with the observer position at spacing:

S =			
	1.0H	6.5 / -24.9	6.5 / -24.9
	1.5H	9.4 / -25.6	9.4 / -25.6
	2.0H	11.4 / -25.8	11.4 / -25.8