Design iGuzzini

iGuzzini

Last information update: March 2025

#### Product configuration: Q941

Q941: Frame recessed luminaire - 15 cells - General Lighting Pro - DALI



#### Product code

Q941: Frame recessed luminaire - 15 cells - General Lighting Pro - DALI

#### Technical description

Rectangular recessed luminaire with 15 optical elements for LED lamps - fixed optics with metallised thermoplastic high definition Opti-Beam reflectors, integrated in a set-back position in the anti-glare screen. Main body with die-cast aluminium radiant surface, version with perimeter surface frame. The total white finish and the patented technology of the optic system guarantee an even and efficient luminous flux optimised by a special diffuser screen that reduces direct glare significantly. Supplied with DALI dimmable electronic control gear connected to the luminaire.

> Weight (Kg) 0.86


## Installation

Recessed with steel wire springs for false ceilings from 1 to 25 mm thick - preparation hole 37 x 406.

Colou	ır
White	(01)


413

Mounting wall recessed ceiling recessed



Technical data					
Im system:	2196	CRI (typical):	97		
W system:	35	Colour temperature [K]:	4000		
Im source:	3050	MacAdam Step:	3		
W source:	31	Life Time LED 1:	50,000h - L90 - B10 (Ta 25°C)		
uminous efficiency (Im/W,	62.7	Lamp code:	LED		
real value):		Number of lamps for optical	1		
Im in emergency mode:	-	assembly:			
Total light flux at or above	0	ZVEI Code:	LED		
an angle of 90° [Lm]:		Number of optical	1		
Light Output Ratio (L.O.R.)	72	assemblies:			
[%]:		Control:	DALI-2		
CRI (minimum):	95				

### Polar



Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	61	57	54	52	56	53	53	50	70
1.0	65	61	58	56	60	57	57	54	75
1.5	69	66	64	62	65	63	62	60	83
2.0	72	69	68	66	68	67	66	64	88
2.5	73	72	70	69	70	69	68	66	92
3.0	74	73	72	71	72	71	70	68	94
4.0	75	74	74	73	73	72	71	69	96
5.0	76	75	74	74	74	73	72	70	97

# Luminance curve limit

QC	Α	G 1	1.15	2000	1000	500		<-300		
	в	1	1.50		2000	1000	750	500	<-300	
	С	1	1.85			2000		1000	500	<-300
85° [				$\left( \right)$		TTY				36
75°		_		ĹĹ						4
			-	$\rightarrow$	$\rightarrow$					2
65										
65° 55°					$\rightarrow$					a h
		8	10 <sup>3</sup>		2	3 4	5 6	8 10	4	

# UGR diagram

Riflec ceil/c walls work Room x	əv pl.	0.70	0.70								
walls work Room	pl.	10.200		0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
work Room	pl.		0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Room	28.2	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
x	Room dim			viewed					viewed		
	У		c	rosswis	e	endwise					
2H	2H	18.3	19.0	18.6	19.2	19.5	18.3	19.0	18.6	19.2	19.5
	3H	18.4	19.0	18.7	19.2	19.5	18.4	19.0	18.7	19.2	19.5
	4H	18.4	18.9	18.7	19.2	19.5	18.3	18.9	18.7	19.2	19.5
	6H	18.4	18.9	18.7	19.2	19.6	18.3	18.8	18.6	19.1	19.4
	8H	18.4	18.9	18.8	19.2	19.6	18.2	18.7	18.6	19.1	19.
	12H	<mark>18.4</mark>	18.9	18.8	19.2	19.6	18.2	18.7	18.6	19.0	19.
4H	2H	18.3	18.9	18.7	19.2	19.5	18.4	18.9	18.7	19.2	19.
	ЗH	18.4	18.9	18.8	19.2	19.6	18.5	19.0	18.9	19.3	19.
	4H	18.5	18.9	18.9	19.3	19.6	18.5	18.9	18.9	19.3	19.
	6H	18.5	18.9	19.0	19.3	19.7	18.4	18.8	18.9	19.2	19.
	BH	18.6	18.9	19.0	19.3	19.7	18.4	18.8	18.9	19.2	19.
	12H	18.6	18.9	19.0	19.3	19.8	18.4	18.7	18.8	19.1	19.
вн	4H	18.4	18.8	18.9	19.2	19.6	18.6	18.9	19.0	19.3	19.
	6H	18.5	18.8	19.0	19.3	19.7	18.6	18.9	19.0	19.3	19.
	HS	18.6	18.8	19.1	19.3	19.8	18.6	18.8	19.1	19.3	19.
	12H	18.6	18.8	19.1	19.3	19.8	18.6	18.8	19.1	19.3	19.1
12H	4H	18.4	18.7	18.8	19.1	19.6	18.6	18.9	<b>19.0</b>	19.3	19.
	бH	18.5	18.8	19.0	19.2	19.7	18.6	18.8	19.1	19.3	19.
	HS	18.6	18.8	<mark>19.1</mark>	19.3	19.8	18.6	18.8	19.1	19.3	19.8
Varia	tions wi	th the ot	oserver p	osition	at spacin	g:					
S =	1.0H		1	.5 / -1.	5			1	.5 / -1.	5	
	1.5H		3	.1 / -3	.4		3	.1 / -3.	4		