


Polar



Isolux




Diagrama UGR

Corrected UGR values (at 810 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceil/cav	walls	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
work pl.	Room dim	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
x	y										
2H	2H	22.4	23.4	22.7	23.6	23.9	22.4	23.4	22.7	23.6	23.9
	3H	22.9	23.8	23.2	24.1	24.3	22.6	23.5	22.9	23.7	24.0
	4H	23.1	23.9	23.5	24.2	24.5	22.6	23.4	23.0	23.7	24.0
	6H	23.3	24.0	23.6	24.4	24.7	22.6	23.3	23.0	23.7	24.0
	8H	23.3	24.1	23.7	24.4	24.8	22.6	23.3	22.9	23.6	24.0
12H	23.4	24.1	23.8	24.4	24.8	22.5	23.2	22.9	23.6	23.9	
4H	2H	22.6	23.4	23.0	23.7	24.0	23.1	23.9	23.5	24.2	24.5
	3H	23.3	23.9	23.6	24.3	24.7	23.4	24.1	23.8	24.5	24.8
	4H	23.6	24.2	24.0	24.5	24.9	23.6	24.2	24.0	24.5	24.9
	6H	23.8	24.4	24.3	24.8	25.2	23.6	24.2	24.1	24.6	25.0
	8H	24.0	24.4	24.4	24.9	25.3	23.7	24.1	24.1	24.6	25.0
12H	24.0	24.5	24.5	24.9	25.4	23.6	24.1	24.1	24.5	25.0	
8H	4H	23.7	24.1	24.1	24.6	25.0	24.0	24.4	24.4	24.9	25.3
	6H	24.0	24.4	24.5	24.9	25.4	24.1	24.5	24.6	25.0	25.5
	8H	24.2	24.6	24.7	25.0	25.5	24.2	24.6	24.7	25.0	25.5
	12H	24.4	24.7	24.9	25.2	25.7	24.3	24.6	24.8	25.1	25.6
12H	4H	23.6	24.1	24.1	24.5	25.0	24.0	24.5	24.5	24.9	25.4
	6H	24.1	24.4	24.6	24.9	25.4	24.3	24.6	24.8	25.1	25.6
	8H	24.3	24.6	24.8	25.1	25.6	24.4	24.7	24.9	25.2	25.7
Variations with the observer position at spacing:											
S =	1.0H	0.4 / -0.6					0.4 / -0.6				
	1.5H	1.0 / -1.4					1.0 / -1.4				
	2.0H	2.0 / -1.8					2.0 / -1.8				